

PHYSICAL TESTING ANALYSIS REPORT

Description: Water Vapour Permeability & Thermal Properties

Test Method: EN771-6 (EN1745)

Ceram Reference: (135405)-22969

Client: Birchover Stone Ltd
Capstone House
Dunston Way
Off Dunston Road
Chesterfield
S41 9RD

For the Attention of: Mr Nigel Morton

Please find attached the results for the sample(s) recently submitted for analysis.

Opinions and interpretations expressed herein are outside the scope of UKAS Accreditation.



Mr Simon Hall
Author

Ceram Reference: (135405)-22969
Customer Reference: Birchover Gritstone
Description: Natural Stone Masonry



***Determination of Thermal Conductivity
Tested in Accordance with EN 1745: Annex A Masonry and Masonry Products,
Methods for Determining Design Thermal Values***

<i>Thermal Conductivity (W/m.k)</i>
1.76

Taken from tabulated values based on values determined from EN 772-13: 2000

End of Test Report