

PHYSICAL TESTING REPORT

ceram

Queens Road, Penkhull, Stoke-on-Trent,
Staffordshire, ST4 7LQ, UK



0013

Birchover Stone Ltd
Capstone House
Dunston Way
Off Dunston Road
Chesterfield
S41 9RD

tel: (customer enquiries) +44 (0)1782 764428
tel: (switchboard) +44 (0)1782 764444
fax: +44 (0)1782 412331
email: enquiries@ceram.com
web: www.ceram.com

**From 1st February 2014 Lucideon will be the
new name for Ceram - www.lucideon.com**

FAO: Mr Nigel Morton

Report of Tests on: Natural Stone Masonry

Your Reference: Birchover Gritstone

Ceram Reference: (135405)-22969

Date Reported: 17-Dec-2013

Order Number: 08091

Date Logged: 22-Oct-2013

Date(s) of Test(s): 11-Dec-2013 to 12-Dec-2013


Determination of Flexural Strength (Before Freeze Thaw)

BS EN 771-6: 2011 (EN 12372: 1999)

	Modulus of Rupture
No.	MPa
1	6.5
2	6.3
3	5.9
4	6.1
5	4.0
6	5.9
7	6.2
8	6.5
9	6.1
10	6.2
Mean	6.0

Opinions and interpretations expressed herein are outside the scope of UKAS Accreditation.

End of Test Report


Mr Graham Doe
Author

PHYSICAL TESTING REPORT

ceram

Queens Road, Penkhull, Stoke-on-Trent,
Staffordshire, ST4 7LQ, UK



0013

Birchover Stone Ltd
Capstone House
Dunston Way
Off Dunston Road
Chesterfield
S41 9RD

tel: (customer enquiries) +44 (0)1782 764428
tel: (switchboard) +44 (0)1782 764444
fax: +44 (0)1782 412331
email: enquiries@ceram.com
web: www.ceram.com

**From 1st February 2014 Lucideon will be the
new name for Ceram - www.lucideon.com**

FAO: Mr Nigel Morton

Report of Tests on: Natural Stone Masonry

Your Reference: Birchover Gritstone

Ceram Reference: (135405)-22969

Date Reported: 17-Dec-2013

Order Number: 08091

Date Logged: 22-Oct-2013

Date(s) of Test(s): 11-Dec-2013 to 13-Dec-2013


Determination of Flexural Strength (After Freeze Thaw)

BS EN 771-6: 2011 (EN 12372: 1999)

	Modulus of Rupture
No.	MPa
1	5.3
2	5.7
3	4.7
4	6.2
5	4.8
6	4.5
7	5.7
8	5.2
9	5.3
10	5.8
Mean	5.3

Opinions and interpretations expressed herein are outside the scope of UKAS Accreditation.

End of Test Report


Mr Graham Doe
Author